

Example^a44
203Initial Notification of Applicability^b

REC'D

National Emission Standards for Hazardous Air Pollutants:

JUL 29 2010

Stationary Reciprocating Internal Combustion Engines

APCO

40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 92114 - Executive & Legislative offices, combinedCompliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startupNote: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of StaffordFacility name (if different): Stafford Municipal Power PlantFacility (physical location) address: 519 S Boston, Stafford Kansas
67628My facility is a (please choose one): ☒ Major source ☐ Area source
☒ Synthetic minor

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Example^aOwner name/title: City of StaffordOwner/company address: P.O. Box 280 Stafford Kansas67578,Owner telephone number: 1-620-234-5011

Owner email address (if available): _____

If the Operator information is different from the Owner, please provide the following:

Operator name/title: Shawn BurgoyOperator telephone number: 620-234-5801

Operator email address (if available): _____

I hereby certify that the information presented herein is correct to the best of my knowledge.

Shawn Burgoy
(Signature)7-23-10
(Date)Plant Foreman
(Name/title)(620) 234 5801
(Telephone No.)

Engines at Plant

800kw Engine 1 - Fairbanks Morse - 38DD8's 8 cylinder D-F

800kw Engine 2 - Fairbanks Morse - 38DD8's 8 cylinder D-F

700kw Engine 3 - EMD - 567D V12 D-F

1365kw Engine 4 - Fairbanks Morse 38DD8's 12 cylinder D-F

1136kw Engine 5 - Fairbanks Morse 38DD8's 10 cylinder D-F